

MANUFACTURER'S DECLARATION OF CONFORMITY

We:

Novotechnik Messwertaufnehmer OHG
Horbstraße 12
73760 Ostfildern (Ruit)

declare under our own responsibility that the product(s):

Product Type: IO-Link Device

Product family: *MC1-2800 Series*

Product Types: **MC1-28aa-244-A11-bbb**

Key:

aa: 02, 32, 62, 21, 41, 71 (e.g. mechanical versions)

bbb: 252, 256, 260, 551 (e.g. electrical connections)

to which this declaration refers conform to:

- ☒ IO-Link Interface and System Specification, V1.1.3, June 2019
(NOTE 1,2)
- ☒ IO Device Description, V1.1.3, January 2021
- ☒ Additional conformance to Device Profiles
(If checked refer to Part A on page 2)
- ☒ Conformance exceptions
(If checked refer to Part B on page 2)

The conformity tests are documented in the test report(s):

Multiturn IO-Link Test V1.2.0 Report

Issued at Ostfildern, 16.04.2025

Authorized signatory

Name: Torsten Wegner
Title: Geschäftsführung CEO
Signature: 

Reproduction and all distribution without written authorization prohibited

NOTE 2 Additional validity in Package 2020 and Corrigendum	
--	--

Part A - Additional conformance to Device Profiles

	Specification
<input checked="" type="checkbox"/>	IO-Link Common Profile Specification, V1.1, Dec. 2021
<input type="checkbox"/>	IO-Link Profile BLOB Transfer & Firmware Update Specification, V1.1, Sept. 2019
<input type="checkbox"/>	IO-Link Smart Sensors 2 nd Edition Specification, V1.1, Sept. 2021

Part B - Conformance exceptions

We herewith declare the following deviations to the related specifications	Reason
The device does not support the command Application Reset (IO-Link Interface and System Specification)	Every cycle, data is updated. No Application Reset really needed

Annex – Conform products

<>

